# BIG WINDOWS. BIG FLOORS. BIG IDEAS.



# **BUILDING SPECIFICATIONS**

### HVAC

- Two cell induced draft cooling towers with pumps and heat exchangers
- Two high efficiency gas fired hot water boilers for space heating
- Central Building Management and Control System
- Two water cooled DX air conditioning units per floor
- Overhead heating system to be provided by tenant; hot water will be provided by Landlord
- Toilet exhaust system for core toilets
- Heated, cooled and filtered outside air system for ventilation

## FI FCTRICAL

- 120/208 volt electrical service in cellar provided by Coned
- Two electrical closets per floor
- 10 watts of connected load per usf for lighting, receptacles and HVAC equipment

# **EMERGENCY POWER**

- 500 KW oil-fired roof emergency generator for life safety

### LIFE SAFETY

- Fully sprinklered building with "wet" fire standpipes
- Addressable automatic Fire Alarm System

## **PLUMBING**

- Plumbing Systems for core toilets

### FI FVATORS

- 4 passenger elevators serving L-Roof, 2 of which serve B-Roof; 4,000 lbs capacity
- 1 freight elevator serving B-Roof; 6,000 lbs capacity

# TEST FIT—TAMI




# **59,636 TOTAL RSF**

SI	EΑ	TΙ	Ν	G
O	-		1 4	U

Workstation	304
Office	8
Total Occupancy	312
COLLABORATIVE	
Enclosed Conference	156
Open Collaboration	260
Total Collaboration	416
RATIOS	
Workstation : Office	97% : 3%
Workplace : Collab.	0.8 : 1





ELEVENTH AVENUE


# TEST FIT—FINANCIAL




# 59,636 TOTAL RSF

Workplace: Collab.

SEATING	
Workstation	348
Office	31
Total Occupancy	379
COLLABORATIVE	
Enclosed Conference	132
Open Collaboration	92
Total Collaboration	224
RATIOS	
Workstation : Office	92% : 8%





ELEVENTH AVENUE

1.7:1

# TEST FIT—TECH




# **59,636 TOTAL RSF**

SE	$\Delta T$	IN	(-
ᇇᆫ	$\neg$	IIN	L

Workstation	380
Hot Seats	60
Office	0
Reception	0
Total Occupancy	440
COLLABORATIVE	
Enclosed Conference	245
Open Collaboration	124
Total Collaboration	369
RATIOS	
Workstation : Office	1:0
Workplace : Collab.	1.1:1






ELEVENTH AVENUE

# FLOOR 8 **CORE & SHELL PLAN**



59,636 TOTAL RSF



# TEST FIT—TECH



# 13,969 TOTAL RSF


Conf. Room Seat to Persons

Open Colab Seat to Persons

# SEATING

02/11110	
Workstation	90
Reception	1
Total Occupancy	91
COLLABORATIVE	
Enclosed Conference	29
Open Collaboration	48
Phone	4
Total Collaboration	81
RATIOS	

54TH STREET



KEY

Office Enclosed Conference Open Collaboration

Core

Circulation

Support

ELEVENTH AVENUE

1:3.1

1:1.9

**55TH STREET** 

# TEST FIT—OFFICE

FLOOR 10



# 13,969 TOTAL RSF

SEATI	٧	G
-------	---	---


Workstation	48
Office	Γ.
Reception	-
Total Occupancy	56
COLLABORATIVE	

Total Collaboration	45
Phone	3
Open Collaboration	4
Enclosed Conference	38

# **RATIOS**

Office to Workstation	1:6.9
Conf. Room Seat to Perso	ons 1:1.5
Open Colab Seat to Perso	ons 1:14

54TH STREET



KEY

Office Enclosed Conference Open Collaboration

Support Core

Circulation

ELEVENTH AVENUE

**55TH STREET**